

November 19, 2024

Rita McNeil  
Harborview Early Learning Center  
45 Market St.  
Perth Amboy, NJ 08861

Dear Ms. McNeil,

Attached please find the certified analysis for:

CRC071737-24  
Harborview Early Learning Center  
45 Market St.  
Perth Amboy, NJ

CRC Services sampled the drinking water supply on November 12, 2024, for copper in accordance with NJDEP Child Care facility and NJ Department of Children and Families (NJDCF) sampling and analysis requirements. CRC Services is certified by the NJDEP for sampling and analysis, Cert. No. 13038.

All samples were taken as “first draw” samples. The facility posted signs at each water outlet in the building to not use the water, or had personal stationed at the facility in order to ensure the water was not used for a minimum of eight hours prior to sampling.

The highest result of the analysis for copper was 112.0 ug/l, which is below the NJDEP maximum contaminant level (MCL) of 1300 ug/l. The water meets NJDEP drinking water standards for copper.

The highest result of the analysis for lead was 2.00 ug/l, which is below the NJDEP maximum contaminant level (MCL) of 15.0 ug/l. The water meets NJDEP drinking water standards for lead.

Please call me if you have any questions, and thank you for using CRC Services.

Sincerely,



Russell A. Creange

Attachments: Certified analysis and chain of custody